

THE MEASURABLE DIFFERENCE.



DEWETRON

OXYGEN TRAINING > POWER





- > General Features
- > Creating a Power Group
- > Delay Compensation
- > Wiring Types
- > Sync Settings
- > Data Visualization
- > Harmonics & Interharmonics
- > Higher Frequency Grouping
- > Supraharmonics
- > Voltage Fluctuation
- > Flicker
- > Mechanical Power
- > dQ Analysis
- > Rolling Computations
- > Realtime Calculations



DEWETRON

GENERAL FEATURES

Benefits of a DEWTRON POWER ANALYZER

- > Full flexible input configuration
- > Simple setup within seconds
- > Individual phase groups (up to 9 phases per PowerGroup)
- > Free selectable sync channel
- > Unlimited recording (only limited by harddisk space)

Type	Hardware	Bandwidth	Samplerate	Phasecount
DEWE3-PA8	TRION3-1810M-POWER-4	5 MHz	10 MS/s	16
DEWE2-PA7	TRION-1820-POWER-4	5 MHz	2 MS/s	12
DEWE2-A7	TRION-1820-POWER-4	5 MHz	2 MS/s	12
DEWE2-A4L	TRION-1820-POWER-4	5 MHz	2 MS/s	8

In addition to the great measurement functions of OXYGEN, the POWER-Option enables the detailed analysis of the phase values and total values in L-N configuration (each total and fundamental):

- > Voltage (RMS, AVG, PHI, Peak-Peak) → OPT-POWER-BASIC
- > Current (RMS, AVG, PHI, Peak-Peak) → OPT-POWER-BASIC
- > Active Power (AVG, PHI) → OPT-POWER-BASIC
- > Reactive Power (AVG) → OPT-POWER-BASIC
- > Apparent Power (AVG) → OPT-POWER-BASIC
- > Power Factor (AVG) → OPT-POWER-BASIC
- > Fundamental Frequency (0.2 – 200 kHz) → OPT-POWER-BASIC
- > Harmonics (up to 1000th order) → OPT-POWER-ADV
- > Interharmonic (up to 1000.5th order) → OPT-POWER-ADV
- > Higher Frequencies (2-9 kHz Grouping) → OPT-POWER-ADV
- > Voltage Fluctuation → OPT-POWER-ADV
- > Flicker Emission → OPT-POWER-ADV
- > Mechanical Power Computation → OPT-POWER-ADV



DEWETRON

© DEWETRON GmbH | August 26

CREATING A POWER GROUP

- 1 Open the Channel List
- 2 Select the desired Sample Rate (min. 10 kHz, calculation disabled below)
- 3 If current transducers are used, open the scaling menu of the current channel and enter the scaling factor
- 4 Press the Add Power Group button

The screenshot shows the DEWETRON software interface. The top panel displays the hardware setup with various input channels. The main panel shows a list of channels under the 'LocalNode' section. The 'TRION-BASE' section is expanded, showing a list of channels including 'U1', 'U2', 'U3', 'I1', 'I2', 'I3', 'AI 2/U3', and 'AI 2/U4'. The 'AI 2/U4' channel is selected. The 'Channel Scaling' dialog box is open, showing the 'Scaling' tab. The 'Unit' is set to 'V', the 'Scaling' is set to '1 V/V', and the 'Offset' is set to '0 V'. The 'Zero' button is visible next to the offset field. The 'Add Power Group' button is located at the bottom of the channel list.

Channel Scaling

Scaling 2-point Table

☒ Scaling ☐ Sensitivity

Unit

Scaling V/V

Offset V



DEWETRON

© DEWETRON GmbH | August 26

DELAY COMPENSATION – TRION-POWER- CURRENT INPUT

AMPLIFIER OPTIONS

Mode	Voltage
Range	10 V
LP filter	Auto
	8 Butterworth
Delay compensation	0 ^① nsec
Effective delay comp.	0 ^② nsec


Current and voltage signals are often not perfectly synchronous due to group delays from the sensors.

To compensate this delay (phase shift) between voltage and current input, a new function was added to the TRION-POWER hardware. This function is also known as Deskew.

① Input field for target delay compensation in nanoseconds (ns). Allowed range is +/-10000ns. Negative Values shifts the current backwards in time, positive forward.

② Display of effective set delay compensation, the resolution is fixed to 100ns.


Before adding a compensation value, in this example (Sine Signal with 1 kHz fundamental frequency), the current lags a few degree. This can be seen in the scope as well as in the phase shift of the fundamental:



After adjusting the value to

$$t = \frac{1}{1000\text{Hz}} \cdot \frac{1}{360^\circ} \cdot (-1.074^\circ) \cdot 10^9 = -2983\text{ns} \quad (6.1)$$

the result is now nearly perfect:





POWER GROUP SETTINGS – WIRING TYPE



DEWETRON

- ① Select the correct Wiring type of the DUT
Wiring schematics below will demonstrate the individual wiring
- ② Assign the current and voltage channels from the Channel List to the Power Group via drag and drop
- ③ Overview of the predefined schematics available here;
Additional information and connection schemes can be found in the manuals



© DEWETRON GmbH | August 26

-
- The screenshot displays the DEWETRON PowerLab software interface for configuring a 3-phase power measurement. The interface is divided into three main sections:
- Left Sidebar (Tree View):** Contains a hierarchical list of measurement categories. The 'Voltage (U)' category is expanded, showing sub-items like 'Total RMS', 'Fundamental', 'Average / PP', 'Symmetrical Components', 'Harmonics', 'Interharmonics', and 'Higher Frequency Grouping'. The 'Current (I)' category is also expanded, showing 'Total RMS', 'Fundamental', 'Average / PP', 'Symmetrical Components', 'Harmonics', 'Interharmonics', and 'Higher Frequency Grouping'. The 'Active Power (P)' category is expanded, showing 'Total', 'Fundamental', and 'Harmonics'. The 'Reactive Power (Q)' category is expanded, showing 'Total', 'Fundamental', and 'Harmonics'. The 'Apparent Power (S)' category is expanded, showing 'Total', 'Fundamental', and 'Harmonics'.
 - Central Workspace:** Displays a wiring diagram for a 3-phase system. The diagram shows three phases (L1, L2, L3) connected to a common neutral (N). Each phase is connected to a load (U1_n, U2_n, U3_n) through a current transformer (CT). The CTs are labeled 'U1_n', 'U2_n', and 'U3_n'. The loads are labeled 'U1_n', 'U2_n', and 'U3_n'. The diagram also shows the power supply (16.04A) and the power consumption (3.62kW) for each phase.
 - Right Sidebar (Measurement List):** Contains a detailed list of measurement parameters and their units. The 'Voltage (U)' category is expanded, showing sub-items like 'Total RMS', 'Fundamental', 'Average / PP', 'Symmetrical Components', 'Harmonics', 'Interharmonics', and 'Higher Frequency Grouping'. The 'Current (I)' category is also expanded, showing 'Total RMS', 'Fundamental', 'Average / PP', 'Symmetrical Components', 'Harmonics', 'Interharmonics', and 'Higher Frequency Grouping'. The 'Active Power (P)' category is expanded, showing 'Total', 'Fundamental', and 'Harmonics'. The 'Reactive Power (Q)' category is expanded, showing 'Total', 'Fundamental', and 'Harmonics'. The 'Apparent Power (S)' category is expanded, showing 'Total', 'Fundamental', and 'Harmonics'.
- Red arrows and circles highlight specific configuration steps:
- Arrow 1:** Points to the 'Total RMS' item under the 'Voltage (U)' category in the left sidebar.
 - Arrow 2:** Points to the 'U12_tRMS' item under the 'Fundamental' category in the right sidebar.
 - Arrow 3:** Points to the 'U12_tRMS' item under the 'Average / PP' category in the right sidebar.



DEWETRON

POWER GROUP SYNC SETTINGS

- ① Synchronization Channel for fundamental frequency detection; Freely definable, per Default Voltage of Phase 1
- ② Minimum fundamental frequency input field ($0.2 \text{ Hz} - f_{\text{max}}$)
- ③ Maximum fundamental frequency input field ($f_{\text{min}} - 0.1 \cdot \text{SR} [\text{Hz}]$)
- ④ Threshold of the amplitude of the synchronization channel that needs to be exceeded for fundamental frequency detection, per default $>0.1\%$
- ⑤ Maximum update rate of the output channels, 1ms per default; 1 ... 5000 ms
- ⑥ For DC applications, Update rate for power calculations
- ⑦ Subsampling factor selection for calculation load reduction

Wiring type [Settings](#)

SYNC SETTINGS

Calculation sync source:

☒ Input channel:

AI 1/U1 Sim ①

Minimum fundamental frequency: Default ②

Maximum fundamental frequency: Default ③

Minimum detection threshold: Default ④

Maximum update rate: Default ⑤

☐ Time interval: 200 ⑥ ms

Channel Subsampling: Auto ⑦

Samplerate	Subsampling Factor
$\leq 2 \text{ MS/s}$	1 (= no Subsampling)
$> 2 \text{ MS/s} - 4 \text{ MS/s}$	2
$> 4 \text{ MS/s} - 6 \text{ MS/s}$	3
$> 6 \text{ MS/s} - 8 \text{ MS/s}$	4
$> 8 \text{ MS/s}$	5

Samplerate	Minimum Fundamental
< 10 kHz	None
10 kHz - 20 kHz	0.2 Hz
20 kHz - 1 MHz	0.2 Hz
1 MHz - 2 MHz	0.5 Hz
2 MHz - 4 MHz	1 Hz
> 5 MHz	2 Hz

Minimum fundamental frequency


This input field holds the setting for the minimum fundamental frequency in Hz which can be measured (lower limit). The following settings are available:

- **Default:** Standard setting, uses 0.2 Hz internally (up to 1MS/s) and $>0.5 \text{ Hz}$ above. The actual value is the lower bound of the F_{fund} channel range.
- **0.2 .. f_{max} Hz:** User defined setting, the possible range is between Default and 100 Hz.

Maximum fundamental frequency

This input field holds the setting for the maximum fundamental frequency in Hz which can be measured (upper limit) The following settings are available:

- **Default:** Standard setting, uses 1500 Hz internally ($>20 \text{ kS/s}$). The actual value is the upper bound of the F_{fund} channel range.
- **Auto:** Uses 1/10 of Samplerate
- **$f_{\text{min}} .. \text{Samplerate}/10 \text{ Hz}$:** User defined setting, the possible range is between f_{min} and 1/10 of Samplerate.







DATA VISUALIZATION



DEWETRON

- ① Power instrument for general data overview
- ② Drag and drop Power group to the instrument to get an RMS value overview
- ③ Or a vectoral visualisation of the voltages and currents
- ④ All Power channels can be added to others displays like Recorders or Meters




DATA VISUALIZATION – Power Group Template



DEWETRON

- ① Open the Screens menu and click on the magic wand icon
- ② Select Power Module and the respective power group you want to display
- ③ A new screen with 4 instruments is added by the template
 - Power instrument table
 - Power instrument Vector view
 - Chart recorder with Voltages
 - Chart recorder with Currents










DEWETRON

© DEWETRON GmbH | August 26

HARMONICS

- 1 Enable Harmonics calculation
- 2 Select a harmonics grouping type
- 3 Specify the maximum harmonics order 1 ... 1000; Default: 50
- 4 Specify the maximum THD harmonics order; 1 ... 1000; Default: 40
- 5 Optionally enable supra harmonics
- 6 Optionally enable calculation of Voltage Line-Line Harmonics & THD
- 7 Optionally enable the relative harmonics channels. They are either normalized by the fundamental or total RMS values
- 8 Optionally create impedance RXZ harmonics channels






DEWETRON

© DEWETRON GmbH | August 26

HARMONICS VISUALIZATION

- 1 Additional window in the Power Instrument for Harmonics
- 2 Higher frequencies can be enabled in instrument settings
- 3 Cursors can be enabled in instrument settings to select a distinct order
- 4 For the selected harmonic order the RMS, percent of fundamental or phase angle can be displayed





DEWETRON

© DEWETRON GmbH | August 26

HARMONICS TABLE

- ① Voltage Harmonics table included in Power Instrument
- ② Current Harmonics table included in Power Instrument
- ③ Power Harmonics table included in Power Instrument
- ④

1

2

3

POWER/O

Phase 1 (THD: 5.13%)				Phase 2 (THD: 11.07%)				Phase 3 (THD: 4.78%)			
Order	RMS	%	PHI	RMS	%	PHI	RMS	%	PHI		
0	5.38V	5.85%	-180.00°	8.96V	11.01%	0.00°	3.58V	4.10%	-180.00°		
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
32											
33											
34											
35											
36											
37											
38											
39											
40											
41											
42											
43											
44											
45											
46											

POWER/O

Phase 1 (THD: 24.46%)				Phase 2 (THD: 9.94%)				Phase 3 (THD: 7.70%)			
Order	RMS	%	PHI	RMS	%	PHI	RMS	%	PHI		
0	108.29mA	1.00%	0.00°	36.42mA	24.71%	-180.00°	52.56mA	33.53%	-180.00°		
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											
11											
12											
13											
14											
15											
16											
17											
18											
19											
20											
21											
22											
23											
24											
25											
26											
27											
28											
29											
30											
31											
32											
33											
34											
35											
36											
37											
38											
39											
40											
41											
42											
43											
44											
45											
46											

Phase 1				Phase 2				Phase 3			
Order	RMS	%		RMS	%		RMS	%			
0	-582.31mW	-17.27%		-326.40mW	-4.21%		188.42mW	6.91%			
1	3.37W	100.00%		7.75W	100.00%		2.73W	100.00%			
2	-58.90mW	-1.75%		-85.81mW	-1.11%		25.88mW	0.95%			
3	-6.48mW	-0.19%		-8.69mW	-0.11%		929.06μW	0.03%			
4	-400.30μW	-0.01%		397.29μW	0.01%		511.47μW	0.02%			
5	-9.55μW	-0.00%		47.50μW	0.00%		384.33μW	0.01%			
6	-31.62μW	-0.00%		177.74μW	0.00%		138.66μW	0.01%			
7	25.86μW	0.00%		150.64μW	0.00%		7.77μW	0.00%			
8	-70.94μW	-0.00%		-648.29μW	-0.01%		261.08μW	0.01%			
9	-55.63μW	-0.00%		38.61μW	0.00%		120.66μW	0.00%			
10	-2.78μW	-0.00%		-42.58μW	-0.00%		17.72μW	0.00%			
11	-11.21μW	-0.00%		-48.97μW	-0.00%		-36.13μW	-0.00%			
12	-9.11μW	-0.00%		26.08μW	0.00%		-159.09mW	-0.00%			
13	18.35μW	0.00%		-44.58μW	-0.00%		15.16μW	0.00%			
14	-690.84nW	-0.00%		-3.39μW	-0.00%		536.32nW	0.00%			
15	-703.32nW	-0.00%		-8.74μW	-0.00%		-3.53μW	-0.00%			
16	6.39μW	0.00%		16.12μW	0.00%		-5.62μW	-0.00%			
17	-750.26nW	-0.00%		-15.43μW	-0.00%		12.08μW	0.00%			
18	-3.56μW	0.00%		18.49μW	0.00%		7.46μW	0.00%			
19	-88.75nW	-0.00%		17.85μW	0.00%		-4.87μW	-0.00%			
20	-1.49μW	-0.00%		-8.53μW	-0.00%		1.55μW	0.00%			
21	930.35nW	0.00%		6.19μW	0.00%		-687.86nW	-0.00%			
22	-401.56nW	-0.00%		-3.96μW	-0.00%		-4.30μW	-0.00%			
23	-1.14μW	-0.00%		3.87μW	0.00%		-2.12μW	-0.00%			
24	1.48μW	0.00%		555.68nW	0.00%		-2.17μW	-0.00%			
25	-329.03nW	-0.00%		-1.72μW	-0.00%		1.18μW	0.00%			
26	-463.26nW	-0.00%		1.04μW	0.00%		144.55nW	0.00%			
27	377.78nW	0.00%		-1.52μW	-0.00%		-286.50nW	-0.00%			
28	93.35nW	0.00%		1.21μW	0.00%		772.65nW	0.00%			
29	-57.01nW	-0.00%		1.76μW	0.00%		-965.00nW	-0.00%			
30	281.23nW	0.00%		-531.62nW	-0.00%		-37.29nW	-0.00%			
31	407.21nW	0.00%		1.39μW	0.00%		-184.77nW	-0.00%			
32	24.33nW	0.00%		-706.72nW	-0.00%		822.62nW	0.00%			
33	205.10nW	0.00%		282.37nW	0.00%		-553.94nW	-0.00%			
34	850.72nW	0.00%		1.23μW	0.00%		461.18nW	0.00%			
35	-16.06nW	-0.00%		-1.33μW	-0.00%		572.09nW	0.00%			
36	49.92nW	0.00%		-319.41nW	-0.00%		-22.97nW	-0.00%			
37	21.95nW	0.00%		-386.15nW	-0.00%		80.71nW	0.00%			
38	409.42nW	0.00%		348.75nW	0.00%		-688.88nW	-0.00%			
39	2.52nW	0.00%		-97.19nW	-0.00%		-260.65nW	-0.00%			
40	63.96nW	0.00%		-832.32nW	-0.00%		-198.90nW	-0.00%			
41	8.55nW	0.00%		-504.11nW	-0.00%		-231.80nW	-0.00%			
42	84.41nW	0.00%		92.33nW	0.00%		-76.54nW	-0.00%			
43	-18.61nW	-0.00%		-992.81nW	-0.00%		28.65nW	0.00%			
44	39.27nW	0.00%		-38.92nW	-0.00%		34.86nW	0.00%			
45	-80.30nW	-0.00%		-105.73nW	-0.00%		-230.99nW	-0.00%			
46	71.00nW	0.00%		1.77μW	0.00%		130.90nW	0.00%			

DEWETRON

HARMONICS TABLE



DEWETRON

- ① Possibility to display Harmonics, Interharmonics, or both in Power Instrument
- ② Possibility to change font size
- ③ Possibility to align text to left, right, center
- ④ Option to define maximum number of lines per column and to split view into several columns
- ⑤ Possibility to show odd, even or all orders
- ⑥ Possibility to show RMS, percentage of fundamental and or angle. At least one parameter is always shown.

<

HARMONICS LIMIT



DEWETRON

- ① Optionally a limit monitoring per order can be enabled, which works for the voltage, current and power table. The limits can be defined individually per order ④.
- ② Optionally show the max RMS value over the defined RMS window ③.
- ③ Define the RMS window length. This window length determines how long a limit exceedance is held on. (0...120s) If now max RMS level is
- ④ The limit per order can be pasted from other text editors or defined in OXYGEN. The delimiter is „TAB“. For example:
1 „TAB“ 3
2.5 „TAB“ 6
- ⑤ The result of all order limits is displayed on the top right of the table with the timestamp of the last exceedance. The timestamp can be cliked to jump to the event.

POWER_3Phase ⑤

Harmonics

Previous max. RMS over limit at: **5:38.980** All limits: **Fail**

Voltage Order	Limit	Phase 1 (THD: 0.02%)				Phase 2 (THD: 0.02%)				Phase 3 (THD: 0.02%)			
		max. RMS	RMS	%	PHI	max. RMS	RMS	%	PHI	max. RMS	RMS	%	PHI
1	240.00V	230.88V	229.99V	100.00%	0.00°	230.44V	230.01V	100.00%	-120.00°	230.49V	230.00V	100.00%	120.00°
3	2.00V	837.15mV	3.81mV	0.00%	-118.09°	656.96mV	6.63mV	0.00%	11.78°	814.47mV	2.34mV	0.00%	17.91°
5	1.00V	694.21mV	3.69mV	0.00%	136.21°	902.39mV	4.18mV	0.00%	-100.04°	667.98mV	2.93mV	0.00%	-77.72°
7	1.00V	771.67mV	6.97mV	0.00%	118.00°	788.88mV	13.52mV	0.01%	72.62°	978.32mV	1.79mV	0.00%	11.55°
9	990.00mV	732.91mV	11.90mV	0.01%	137.49°	850.30mV	7.46mV	0.00%	-113.09°	740.19mV	5.21mV	0.00%	-97.14°
11	980.00mV	776.45mV	7.49mV	0.00%	-57.07°	688.52mV	9.68mV	0.00%	64.65°	629.34mV	14.22mV	0.01%	137.86°
13	960.00mV	890.88mV	8.94mV	0.00%	3.61°	799.05mV	7.16mV	0.00%	141.24°	700.55mV	1.62mV	0.00%	1.86°
15	940.00mV	730.61mV	5.69mV	0.00%	87.91°	899.87mV	3.73mV	0.00%	8.49°	799.67mV	5.60mV	0.00%	86.99°
17	920.00mV	881.81mV	8.42mV	0.00%	120.29°	752.21mV	6.19mV	0.00%	29.09°	764.67mV	10.64mV	0.00%	30.18°
19	900.00mV	852.56mV	7.98mV	0.00%	101.17°	748.98mV	5.24mV	0.00%	170.26°	762.61mV	7.14mV	0.00%	-17.27°
21	880.00mV	788.36mV	6.75mV	0.00%	-13.83°	972.70mV	6.61mV	0.00%	-124.83°	724.39mV	9.18mV	0.00%	-94.15°
23	860.00mV	805.62mV	8.01mV	0.00%	153.51°	787.31mV	5.97mV	0.00%	11.67°	885.05mV	4.03mV	0.00%	36.11°
25	840.00mV	684.17mV	4.63mV	0.00%	148.36°	691.97mV	13.19mV	0.01%	-137.60°	686.14mV	8.00mV	0.00%	49.59°
27	820.00mV	805.46mV	10.70mV	0.00%	97.12°	697.42mV	9.06mV	0.00%	156.84°	827.62mV	5.38mV	0.00%	-2.23°
29	800.00mV	784.36mV	4.43mV	0.00%	150.36°	943.74mV	14.56mV	0.01%	101.44°	833.63mV	3.57mV	0.00%	28.82°
31	790.00mV	739.65mV	7.10mV	0.00%	179.77°	901.53mV	13.06mV	0.01%	-70.47°	686.21mV	5.33mV	0.00%	-129.77°
33	770.00mV	686.06mV	3.44mV	0.00%	-20.19°	1.05V	2.46mV	0.00%	-76.62°	723.70mV	5.47mV	0.00%	-89.70°
35	750.00mV	767.30mV	13.57mV	0.01%	-26.87°	991.41mV	4.91mV	0.00%	109.89°	1.25V	6.28mV	0.00%	-118.65°
37	730.00mV	835.53mV	5.78mV	0.00%	-125.59°	809.79mV	10.31mV	0.00%	-111.45°	737.50mV	8.40mV	0.00%	-178.18°
39	710.00mV	841.49mV	3.64mV	0.00%	66.33°	710.96mV	8.82mV	0.00%	-12.11°	710.96mV	8.82mV	0.00%	-12.11°
41	690.00mV	1.02V	9.51mV	0.00%	57.94°	807.78mV	11.46mV	0.00%	-17.11°	807.78mV	11.46mV	0.00%	-17.11°
43	670.00mV	841.19mV	4.17mV	0.00%	-40.69°	775.45mV	8.96mV	0.00%	-38.11°	775.45mV	8.96mV	0.00%	-38.11°
45	650.00mV	809.06mV	7.83mV	0.00%	-56.03°	787.94mV	3.25mV	0.00%	-13.11°	787.94mV	3.25mV	0.00%	-13.11°
47	630.00mV	960.05mV	6.98mV	0.00%	73.23°	764.90mV	6.46mV	0.00%	-10.11°	764.90mV	6.46mV	0.00%	-10.11°
49	610.00mV	894.90mV	3.19mV	0.00%	121.62°	776.82mV	13.32mV	0.01%	-41.11°	776.82mV	13.32mV	0.01%	-41.11°

Harmonics limits

☒ Show limit value ①

☒ Show max. RMS level ②

Max. RMS window: 0.5 ③ min.

Voltage: Edit... Copy Paste X

Current: Add... Copy Paste X

Power: Add... Copy Paste X



HARMONICS VISUALIZATION



DEWETRON

© DEWETRON GmbH | August 26

- 1 Drag and drop the Array Chart to the screen...
 - 2 ...and assign any Harmonics channel
- Supports:
- Harmonics
 - Interharmonics
 - Higher Frequency Groupings
 - Supraharmonics





DEWETRON

GROUPING MODE - NONE

ADVANCED SETTINGS

Harmonics Flicker

☐ Harmonics / interharmonics grouping

Grouping type:

☒ None☐ Type 1 - IEC61000-4-7 5.6 (9)☐ Type 2 - IEC61000-4-7 5.5.1 (8)

Maximum harmonic order: 50

Maximum THD harmonic order: 40

Symbol Description

Y_c	RMS Magnitude of FFT-Bin
Y_h	RMS Magnitude of Harmonic Order h (Grouping "None")
$Y_{sg,h}$	RMS Magnitude of Harmonic Order h (Grouping "Type 1")
$Y_{g,h}$	RMS Magnitude of Harmonic Order h (Grouping "Type 2")
NP	Number of fundamental Periods
h	Harmonic Order



- > When this mode is selected, only the harmonic bins are taken for generation of the harmonic data. $Y_h = Y_c[NP \cdot h]$
- > When this mode is selected, all bins (except of harmonic bin) are taken for generation of the interharmonic data.

$$Y_h = NaN$$

$$NP = 1$$

$$Y_h = \sqrt{\sum_{k=1}^{N-1} Y_c[NP \cdot h + k]^2}$$

$$NP > 1$$



GROUPING MODE - TYPE 1 - IEC61000-4-7-5.6



DEWETRON

ADVANCED SETTINGS

Harmonics Flicker Mechanical Rolling Computations

☐ Harmonics / interharmonics grouping

Grouping type:

- ☐ None
- ☒ Type 1 - IEC61000-4-7 5.6 (9)
- ☐ Type 2 - IEC61000-4-7 5.5.1 (8)

Maximum harmonic order: 50

Maximum THD harmonic order: 40

Symbol Description

Y_c	RMS Magnitude of FFT-Bin
Y_h	RMS Magnitude of Harmonic Order h (Grouping "None")
$Y_{sg,h}$	RMS Magnitude of Harmonic Order h (Grouping "Type 1")
$Y_{g,h}$	RMS Magnitude of Harmonic Order h (Grouping "Type 2")
NP	Number of fundamental Periods
h	Harmonic Order

- > When this mode is selected, the harmonics are grouped according to IEC61000-4-7 Section



$$Y_{sg,h} = Y_c[NP \cdot h] \quad NP < 2$$

$$Y_{sg,h} = \sqrt{\sum_{k=-1}^1 Y_c[NP \cdot h + k]^2} \quad NP \geq 2$$

- > When this mode is selected, the Interharmonics are grouped according to

$$Y_{isg,h} = NaN \quad NP \leq 2$$

$$Y_{isg,h} = \sqrt{\sum_{k=2}^{N-2} Y_c[NP \cdot h + k]^2} \quad NP > 2$$



GROUPING MODE - TYPE 2 - IEC61000-4-7-5.5.1



DEWETRON

ADVANCED SETTINGS

Harmonics Flicker Mechanical Rolling Computations

☐ Harmonics / interharmonics grouping

Grouping type:

☐ None

☐ Type 1 - IEC61000-4-7 5.6 (9)

☒ Type 2 - IEC61000-4-7 5.5.1 (8)

Maximum harmonic order: 50

Maximum THD harmonic order: 40

Symbol	Description
Y_c	RMS Magnitude of FFT-Bin
Y_h	RMS Magnitude of Harmonic Order h (Grouping "None")
$Y_{sg,h}$	RMS Magnitude of Harmonic Order h (Grouping "Type 1")
Y_{gh}	RMS Magnitude of Harmonic Order h (Grouping "Type 2")
NP	Number of fundamental Periods
h	Harmonic Order

- > When this mode is selected, the harmonics are grouped according to IEC61000-4-7 Section 5.5.1



$$Y_{gh} = Y_c[NP \cdot h] \quad NP < 2 \quad (7.4)$$

$$Y_{gh} = \sqrt{\frac{1}{2}Y_c \left[NP \cdot h - \frac{N}{2} \right]^2 + \sum_{k=-\frac{N}{2}+1}^{\frac{N}{2}-1} Y_c [NP \cdot h + k]^2 + \frac{1}{2}Y_c \left[NP \cdot h + \frac{N}{2} \right]^2} \quad NP \geq 2 \quad (7.5)$$

- > When this mode is selected, all bins (except of harmonic bin) are taken for generation of the interharmonic data.

$$Y_{igh} = NaN \quad NP = 1$$

$$Y_{igh} = \sqrt{\sum_{k=1}^{N-1} Y_c [NP \cdot h + k]^2} \quad NP > 1$$





DEWETRON

HARMONICS/INTERHARMONICS - OUTPUT CHANNELS

Active Power (P)

Total

Fundamental

Harmonic

P1_h
Power

P1_THP
Power

P2_h
Power

P2_THP
Power

P3_h
Power

P3_THP
Power

Reactive Power (Q)

Total

Fundamental

Harmonic

Q1_h
Power

Q2_h
Power

Q3_h
Power

Apparent Power (S)

Total

Fundamental

Harmonic

S1_h
Power

S2_h
Power

S3_h
Power

Voltage (U)

Total RMS

Fundamental

Average / PP

Symmetrical Components

Harmonics

U1_hRMS
Power

U1_hPHI
Power

U1_THD
Power

U1_THV
Power

U2_hRMS
Power

U2_hPHI
Power

U2_THD
Power

U2_THV
Power

U3_hRMS
Power

U3_hPHI
Power

U3_THD
Power

U3_THV
Power

Interharmonics

U1_ihRMS
Power

U2_ihRMS
Power

U3_ihRMS
Power

Current (I)

Total RMS

Fundamental

Average / PP

Symmetrical Components

Harmonics

I1_hRMS
Power

I1_hPHI
Power

I1_THD
Power

I1_THC
Power

I2_hRMS
Power

I2_hPHI
Power

I2_THD
Power

I2_THC
Power

I3_hRMS
Power

I3_hPHI
Power

I3_THD
Power

I3_THC
Power

Interharmonics

I1_ihRMS
Power

I2_ihRMS
Power

I3_ihRMS
Power

POWER/0
PowerGroup

Voltage (U)

Total RMS

Fundamental

Average / PP

Symmetrical Components

Harmonics

U1_hRMS
U1_hRMS

U1_hPHI
U1_hPHI

U1_THD
U1_THD

U1_THV
U1_THV

U2_hRMS
U2_hRMS

U2_hPHI
U2_hPHI

U2_THD
U2_THD

U2_THV
U2_THV

U3_hRMS
U3_hRMS

U3_hPHI
U3_hPHI

U3_THD
U3_THD

U3_THV
U3_THV

U12_hRMS
U12_hRMS

U12_THD
U12_THD

U23_hRMS
U23_hRMS

U23_THD
U23_THD

U31_hRMS
U31_hRMS

U31_THD
U31_THD

Voltage
Line-Line
Harmonics
& THD

U12_hRMS
U12_THD
U23_hRMS
U23_THD
U31_hRMS
U31_THD



HIGHER FREQUENCY GROUPING



DEWETRON

- > The Higher Frequency Grouping is orientated on fixed frequency bands (see IEC/EN61000-4-7 Appendix B)

$$Y_{B,b} = \sqrt{\sum_{f=b-95\text{Hz}}^{b+100\text{Hz}} Y_{C,f}^2}$$



Symbol	Description
$Y_{C,f}$	RMS Magnitude of FFT-Bin
$Y_{B,b}$	RMS Magnitude of Higher Frequency Order b



DEWETRON

SUPRAHARMONICS

- > Unlike the other grouping methods, the Supraharmonics are aggregated in time
- > Minimum Sample rate = 1 MHz

ADVANCED SETTINGS

Harmonics Flicker Mechanical Rolling Computations

☐ Harmonics / Interharmonics grouping

Grouping type:

☐ None

☐ Type 1 - IEC61000-4-7 5.6 (9)

☒ Type 2 - IEC61000-4-7 5.5.1 (8)

Maximum harmonic order: 50



Maximum THD harmonic order: 40

☐ Enable supra harmonics

Symbol Description

$Y_{C,b}$	RMS Magnitude of FFT-Bin b
$Y_{SH,b,min}$	Minimum RMS Magnitude of Supraharmonics order i
$Y_{SH,b,avg}$	Average RMS Magnitude of Supraharmonics order i
$Y_{SH,b,max}$	Maximum RMS Magnitude of Supraharmonics order i
NP	Number of fundamental periods (10 @ 50Hz, 12 @ 60Hz)
N_{FFT}	Number of Short Time FFTs in time interval of NP
SR	Samplerate

$$N_{FFT} = \frac{NP \cdot SR}{500}$$
$$Y_{SH,b,min} = \min(Y_{C,b})$$
$$Y_{SH,b,avg} = avg(Y_{C,b})$$
$$Y_{SH,b,max} = \max(Y_{C,b})$$



VOLTAGE FLUCTUATION AND FLICKER EMISSION



DEWETRON

© DEWETRON GmbH | August 26

ADVANCED SETTINGS

1 **Harmonics** **Flicker** Mechanical d/q Rolling

☐ Flicker analysis according to IEC61000-4-15:2011

Weighting type: **2**

☒ Autodetection

☐ 230V / 50Hz ☐ 230V / 60Hz

☐ 120V / 50Hz ☐ 120V / 60Hz

Nominal voltage: **3** min.

Aggregation time of Pst: min.

Aggregation time of Plt: min.

Short-circuit apparent power: **4** MVA

Sign convention:

Grid impedance angles °

d-Parameter evaluation

Steady state threshold: %

Steady state window length: s

Steady state detection level: %

Working conditions for voltage fluctuation:

Fundamental Frequency	10 to 1000 Hz
Nominal Voltage	> 5% of Input Range
Weighting Functions	120V/50Hz, 120V/60Hz, 230V/50Hz, 230V/60Hz
Aggregation Time Pst	1 to 60 min
Aggregation Time Plt	1 to 1440 min
Short Circuit Apparent Power	0.001 to 10 000 MVA

Measurement parameters according to IEC61000-4-15 and IEC61400-21 Section 7.3.

Flicker Analysis procedure

- > Switch on the Feature **1**
- > Select the Weighting Type **2** for your Application. Use Autodetection in low voltage grids (120V/230V). If you want to use the Voltage Fluctuation Algorithm outside these Conditions, please select the weighting type manually and insert the nominal voltage in **3**
- > Change the Aggregation Time of Pst and Plt if needed **4**
- > Go back to Measurement Screen, take an indicator instrument and assign the U[i]_fluc_ready Channel
- > Take a Table Instrument and assign the U[i]_fluc_Pst Channels or any other Instrument to visualize the Voltage Fluctuation Values
- > Wait for Channel Ready
- > Start the Recording

VOLTAGE FLUCTUATION AND FLICKER EMISSION

Voltage (U)		
▶ Total RMS		
▶ Fundamental		
▶ Average / PP		
▶ Symmetrical Components		
▶ Harmonics		
▶ Interharmonics		
▶ Higher Frequency Grouping		
Flicker		
U1_fluc_ready		
U1_fluc_Pinst		
U1_fluc_Pst		
U1_fluc_Plt		
U1_fluc_dc		
U1_fluc_d_max		
U1_fluc_td		
U2_fluc_ready		
U2_fluc_Pinst		
U2_fluc_Pst		
U2_fluc_Plt		
U2_fluc_dc		
U2_fluc_d_max		
U2_fluc_td		
U3_fluc_ready		
U3_fluc_Pinst		
U3_fluc_Pst		
U3_fluc_Plt		
U3_fluc_dc		
U3_fluc_d_max		
U3_fluc_td		

Current (I)		
▶ Total RMS		
▶ Fundamental		
▶ Average / PP		
▶ Symmetrical Components		
▶ Harmonics		
▶ Interharmonics		
▶ Higher Frequency Grouping		
Flicker		
I1_fluc_ready		
I1_fluc_Pinst_30		
I1_fluc_Pst_30		
I1_fluc_Plt_30		
I1_fluc_Pinst_50		
I1_fluc_Pst_50		
I1_fluc_Plt_50		
I1_fluc_Pinst_70		
I1_fluc_Pst_70		
I1_fluc_Plt_70		
I1_fluc_Pinst_85		
I1_fluc_Pst_85		
I1_fluc_Plt_85		
I2_fluc_ready		
I2_fluc_Pinst_30		
I2_fluc_Pst_30		
I2_fluc_Plt_30		
I2_fluc_Pinst_50		
I2_fluc_Pst_50		
I2_fluc_Plt_50		
I2_fluc_Pinst_70		
I2_fluc_Pst_70		
I2_fluc_Plt_70		
I2_fluc_Pinst_85		
I2_fluc_Pst_85		
I2_fluc_Plt_85		

Output Channels:

Parameters according to

IEC61000-4-15 and
IEC61400-21 Section 7.3.

I3_fluc_ready		
I3_fluc_Pinst_30		
I3_fluc_Pst_30		
I3_fluc_Plt_30		
I3_fluc_Pinst_50		
I3_fluc_Pst_50		
I3_fluc_Plt_50		
I3_fluc_Pinst_70		
I3_fluc_Pst_70		
I3_fluc_Plt_70		
I3_fluc_Pinst_85		
I3_fluc_Pst_85		
I3_fluc_Plt_85		

8.5.1 U[i]_fluc_Pst

The short-term flicker severity

8.5.2 U[i]_fluc_Plt

The long-term flicker severity

$$U[i]_{fluc_Plt} = \sqrt[3]{\frac{1}{N} \sum_{k=0}^{N-1} U[i]_{fluc_Pst}[k]^3} \quad \text{Unit : A} \quad (8.148)$$

8.5.3 U[i]_fluc_Pinst

The instantaneous flicker sensation

8.5.4 U[i]_fluc_ready

Indicator value for steady state of algorithm filters

8.5.5 I[i]_fluc_Pst_[ψ]

The short-term flicker emission severity according to IEC61400-21. Equal to $P_{st, fic}$. $\psi \in [30^\circ, 50^\circ, 70^\circ, 85^\circ]$

8.5.6 I[i]_fluc_Plt_[ψ]

The long-term flicker emission severity. $\psi \in [30^\circ, 50^\circ, 70^\circ, 85^\circ]$

8.5.7 I[i]_fluc_Pinst_[ψ]

The instantaneous flicker emission sensation. $\psi \in [30^\circ, 50^\circ, 70^\circ, 85^\circ]$

8.5.8 U[i]_fluc_dc

Steady state voltage change

8.5.9 U[i]_fluc_dmax

Maximum voltage change during a voltage change characteristic

8.5.10 U[i]_fluc_td

Duration of Voltage change below 3.3%.

8.5.11 U[i]_fluc_fic_[ψ]_hp_RMS

The Phase's i half period RMS value of the fictitious grid, used for Stage 1 in the IEC-Flickermeter. Can be used to calculate the Voltage change factor k_u . $\psi \in [30^\circ, 50^\circ, 70^\circ, 85^\circ]$



DEWETRON

FLICKER EMISSION – THEORETICAL BACKGROUND

Sign convention:

Grid impedance angles


d-Parameter evaluation

Steady state threshold: %

Steady state window length: s

Steady state detection level: %

- > Short Term Voltage fluctuations evaluate the voltage change characteristics according to IEC61000-4-15. For this analysis, the half-period rms values from the voltage channels are calculated internally.
- > Explanation of the evaluation of the d-Parameter




- > d-Parameters can be modified since Oxygen 6.6

Symbol	Description
$S_{K,fic}$	This is the short circuit power of the fictitious grid. To be given for one phase in MVA!
U_N	Nominal Voltage (U_{L-N}) of the analyzed grid.
ψ_K	Phase Angle of the Grid Impedance (pre-defined with 30/50/70/85 deg)
R_{fic}	Fictitious Ohmic impedance
X_{fic}	Fictitious Reactive impedance
f_N	Nominal Frequency (50 or 60 Hz, depending on the selected Weighting)

$$S_{K,fic} = \frac{U_N^2}{\sqrt{R_{fic}^2 + X_{fic}^2}} \quad \text{Unit : VA}$$
$$Z_{fic} = \sqrt{R_{fic}^2 + X_{fic}^2} = \frac{U_N^2}{S_{K,fic}} \quad \text{Unit : } \Omega$$
$$R_{fic} = Z_{fic} \cdot \cos(\psi_K) \quad \text{Unit : } \Omega$$
$$X_{fic} = Z_{fic} \cdot \sin(\psi_K) \quad \text{Unit : } \Omega$$
$$L_{fic} = \frac{X_{fic}}{2 \cdot \pi \cdot f_N} \quad \text{Unit : H}$$

- > Flicker Emission is the Analysis of the virtually generated voltage fluctuation caused by the emitted current. This analysis procedure is described in the IEC61400-21 Standard. It uses a fictitious grid for simulation of a fictitious voltage, which is then processed with the flicker algorithm to get the Pst, fic.





DEWETRON

FLICKER ANALYSIS – AUTO DETECTION & AGGREGATION TIME

ADVANCED SETTINGS

Harmonics **Flicker**

☒ Flicker analysis according to IEC61000-4-15:2011

Weighting type:

☒ Autodetection

☐ 230V / 50Hz

☐ 230V / 60Hz

☐ 120V / 50Hz

☐ 120V / 60Hz


Nominal voltage: 230 V

Aggregation time of Pst: 10 min


Aggregation time of Plt: 120 min

Short-circuit apparent power: 50 MVA

- The Auto-Detection Mode is useful for the most applications. In the following graph you can see, which Mode is applied under different circumstances.



- Pst/Plt Aggregation Time: If the Recording is started before ready (1), the aggregation is started when ready. When recording is started while ready (2), the aggregation will be started with the recording start..





DEWETRON

FLICKER ANALYSIS – Flicker Table

- New Flicker tab in Power instrument for easy Flicker judgement and reporting (①)
- Evaluation of dc, dmax, Pst and Plt for the Plt aggregation time
- Pass/Fail limits can be defined in Instrument Properties (②)
- Structured overview that can be directly used for reporting
- As soon as one single judgement fails the total judgement fails (③)



CTRL+C to copy data to clipboard supported

Phase 1 judgement: Pass		Total judgement: Pass			
	Limit	dc [%]	dmax [%]	Pst	Plt
	0.300	4.000	1.000	0.650	
Result	0.216	Pass 0.882	Pass 0.517	Pass 0.357	Pass
1	0.180	Pass 0.882	Pass 0.517	Pass	
2	0.077	Pass 0.419	Pass 0.296	Pass	
3	0.135	Pass 0.802	Pass 0.345	Pass	
4	0.126	Pass 0.378	Pass 0.345	Pass	
5	0.150	Pass 0.777	Pass 0.394	Pass	
6	0.094	Pass 0.377	Pass 0.300	Pass	
7	0.090	Pass 0.420	Pass 0.326	Pass	
8	0.200	Pass 0.383	Pass 0.326	Pass	
9	0.216	Pass 0.517	Pass 0.373	Pass	
10	0.192	Pass 0.470	Pass 0.329	Pass	
11	0.174	Pass 0.653	Pass 0.305	Pass	
12	0.062	Pass 0.441	Pass 0.299	Pass	

FLICKER TABLE

Limit dc:

0.3

%

Limit dmax:

4

%

Limit Pst:


1

Limit Plt:

0.65

Phase 1 judgement: Fail		Total judgement: Fail			
	Limit	dc [%]	dmax [%]	Pst	Plt
	0.300	4.000	1.000	0.650	
Result	0.321	Fail 0.918	Pass 0.646	Pass 0.489	Pass
1	0.073	Pass 0.338	Pass 0.268	Pass	
2	0.092	Pass 0.382	Pass 0.274	Pass	
3	0.156	Pass 0.712	Pass 0.452	Pass	
4	0.000	Pass 0.000	Pass 0.569	Pass	
5	0.082	Pass 0.689	Pass 0.528	Pass	
6	0.000	Pass 0.000	Pass 0.634	Pass	
7	0.000	Pass 0.000	Pass 0.646	Pass	
8	0.321	Fail 0.918	Pass 0.487	Pass	
9	0.194	Pass 0.587	Pass 0.571	Pass	
10	0.123	Pass 0.496	Pass 0.409	Pass	
11	0.183	Pass 0.384	Pass 0.295	Pass	
12	0.114	Pass 0.280	Pass 0.284	Pass	

MECHANICAL POWER COMPUTATION + DC-POWER




① Enable/Disable DC power calculation

② Add Voltage U_{DC}

③ Add Current I_{DC}

The **Efficiency** Tab includes DC Power Analysis and Mechanical Power Analysis



Efficiency		
Eff_dc_ac		
Eff_dc_ac		
I_DC		
I_DC		
U_DC		
U_DC		
P_DC		
P_DC		
Eff_mech		
Eff_mech		
Eff_sys		
Eff_sys		

3 different Efficiency maps can be created

U_{DC} vs I_{DC} vs Eff_{dc_ac}

n_{mech} vs M_{mech} vs Eff_{mech}

U_{DC} vs I_{DC} vs Eff_{sys}

- > Channels are updated every calculation cycle given by calculation sync source (same as electrical power).
- > This way, DC-POWER and AC-POWER are synchronised

OXY-OPT-POWER-ADV required

MECHANICAL POWER COMPUTATION + DC-POWER



DEWETRON

© DEWETRON GmbH | August 26

ADVANCED SETTINGS

Harmonics Flicker Efficiency d/q Rolling

☐ DC power analysis

Voltage U_DC | Current I_DC

Drop channel here | Drop channel here

☐ Mechanical power analysis

Name	Rotation speed	Torque	
1	Speed	Torque	+

Add AC -> Mech efficiency map

▼ Mechanical			
P_mech_1			⚙
n_mech_1			⚙
M_mech_1			⚙
P_mech_2			⚙
n_mech_2			⚙
M_mech_2			⚙
▼ Efficiency			
Eff_dc_ac			⚙
I_DC			⚙
U_DC			⚙
P_DC			⚙
Eff_mech			⚙
Eff_sys			⚙

$$P_{mech} = \frac{1}{N} \sum_{n=0}^N speed[n] \cdot torque[n] \cdot \frac{2 \cdot \pi}{60}$$

$$n_{mech} = \frac{1}{N} \sum_{n=0}^N speed[n]$$

$$M_{mech} = \frac{1}{N} \sum_{n=0}^N torque[n]$$

$$Eff_{mech} = \begin{cases} \frac{P_i}{P_{mech}} \cdot 100 & \text{if } P_{mech} < 0 \\ \frac{P_{mech}}{P_i} \cdot 100 & \text{if } P_{mech} \geq 0 \end{cases}$$


- > Channels are updated every calculation cycle given by calculation sync source (same as electrical power).
- > Up to 6 Mechanical Pairs (n & M) can be added.
- > Each Mechanical Power P_{mech_x} is added up to P_{mech} for Efficiency Calculation

OXY-OPT-POWER-ADV required

MECHANICAL POWER COMPUTATION + DC-POWER + MACHINE EXCITATION

- ① Enable DC power analysis, mechanical power analysis, Machine excitation
- ② Input field for rotation speed channel (unit must be rpm)
- ③ Input field for torque channel (unit must be Nm)

If the Machine Excitation is enabled the mechanical efficiency also factors for the power of the machine excitation



$$Eff_{mech} = \begin{cases} \frac{P_{mech}}{P_{t_AC} + P_{exc}} \cdot 100 & \text{if } P_{t_AC} > 0 \\ \frac{|P_{t_AC}|}{|P_{mech}| + P_{exc}} \cdot 100 & \text{if } P_{t_AC} < 0 \text{ and } P_{mech} < 0 \end{cases}$$

Efficiency

Eff_dc_ac

Eff_dc_ac

Eff_mech

Eff_mech

Eff_sys

Eff_sys

DC

P_DC

P_DC

U_DC

U_DC

I_DC

I_DC

Machine Excitation

U_exc

U_exc

I_exc

I_exc

P_exc

P_exc

PowerGroup

POWER/0

Wiring type Settings

SYNC SETTINGS

Calculation sync source:

Input channel:

U1

Minimum fundamental frequency:

Default

Maximum fundamental frequency:

Default

Minimum detection threshold:

Default

Maximum update rate:

Default

Secondary sync source:

Drop channel here

ADVANCED SETTINGS

Harmonics Flicker Efficiency d/q Rolling

DC power analysis

Group

Voltage U_DC

Current I_DC

+

1

U_DC

I_DC

-

Mechanical power analysis

Name

Rotation speed

Torque

+

1

Speed

Torque

-

Machine Excitation

Voltage U_EXC

Current I_EXC

U_exc

I_exc

Add DC -> AC efficiency map

Add AC -> Mech efficiency map

Add DC -> Mech efficiency map

DQ-ANALYSIS



DEWETRON

© DEWETRON GmbH | August 26

ADVANCED SETTINGS

Harmonics Flicker Mechanical d/q Rolling

☒ D/Q Analysis ①

Mechanical angle: angle ②

Number of poles-pairs: 2 ③

Angle offset: 240 ④ Detect

Output samplerate: 100 ⑤ Hz

POWER/0

PowerGroup

> Voltage (U)

> Current (I)

> Active Power (P)

> Reactive Power (Q)

> Apparent Power (S)

> Power Factor (PF)

> Energy (W)

▼ **Mechanical Power**

Ud		
Uq		
Id		
Iq		

- ① Enable dQ analysis feature
- ② Assign the angle channel
- ③ Enter the number of pole-pairs according to your engine
- ④ Drive the DUT with an auxiliary engine at constant speed and press the *Detect* button to measure the angle offset or enter it manually
- ⑤ Define the output rate of the output channels

OXY-OPT-POWER-ADV required

d-Axis Voltage, reduced with block-wise average to given output samplerate.

$$U_d^* = \frac{2}{3} \cdot \left(U_{1N} \cdot \cos(\theta) + U_{2N} \cdot \cos\left(\theta - \frac{2\pi}{3}\right) + U_{3N} \cdot \cos\left(\theta + \frac{2\pi}{3}\right) \right)$$

$$U_d = \frac{red_SR}{SR} \cdot \sum_{i=0}^{SR} U_d^*$$

Unit : V

q-Axis Voltage, reduced with block-wise average to given output samplerate.

$$U_q^* = \frac{2}{3} \cdot \left(-U_{1N} \cdot \sin(\theta) - U_{2N} \cdot \sin\left(\theta - \frac{2\pi}{3}\right) - U_{3N} \cdot \sin\left(\theta + \frac{2\pi}{3}\right) \right)$$

$$U_q = \frac{red_SR}{SR} \cdot \sum_{i=0}^{SR} U_q^*$$

d-Axis Current, reduced with block-wise average to given output samplerate.

$$I_d^* = \frac{2}{3} \cdot \left(I_1 \cdot \cos(\theta) + I_2 \cdot \cos\left(\theta - \frac{2\pi}{3}\right) + I_3 \cdot \cos\left(\theta + \frac{2\pi}{3}\right) \right)$$

$$I_d = \frac{red_SR}{SR} \cdot \sum_{i=0}^{SR} I_d^*$$

q-Axis Current, reduced with block-wise average to given output samplerate.

$$I_q^* = \frac{2}{3} \cdot \left(-I_1 \cdot \sin(\theta) - I_2 \cdot \sin\left(\theta - \frac{2\pi}{3}\right) - I_3 \cdot \sin\left(\theta + \frac{2\pi}{3}\right) \right)$$

$$I_q = \frac{red_SR}{SR} \cdot \sum_{i=0}^{SR} I_q^*$$

ROLLING COMPUTATIONS - GENERAL

ADVANCED SETTINGS

Harmonics Flicker Mechanical d/q **Rolling**

☒ Enable rolling period calculation


Nominal frequency: 50 Hz

Nominal frequency threshold: 10 %

Update rate: 1 ms

Window length: 1 cycles


The following graph shows the details of the operation principle. It is similar to a moving average calculation, but with a variable window size, which depends on the actual measured fundamental frequency. If the calculate window size exceeds the maximum allowed size, which is given by $(1/\text{Nominal Frequency}) \cdot (1 + \text{Frequency Threshold}/100)$, the window size is set to $1/\text{Nominal Frequency}$.



Usecase: Testing of Renewable Energy Sources according to IEC 61400-21 and FGW-TR3 where some tests require the analysis of fast transitions

- ① Enable/Disable Rolling Calculation
- ② Selector for nominal frequency fallback
- ③ Input field for frequency threshold. If a frequency is detected within the nominal frequency threshold %, the rolling window size is the actual period duration. Otherwise, e.g. in the case of a voltage interruption, where no frequency can be measured, the window size is the inverse nominal frequency.

ROLLING COMPUTATIONS – OUTPUT CHANNELS






DEWETRON

© DEWETRON GmbH | August 26

ROLLING COMPUTATIONS – EXAMPLE 60 HZ GRID

- > Whenever the voltage drops the frequency cannot be detected anymore and the calculation interval switches to a fixed time. The last calculated value (U1_tRMS in figures) can be seen at marker A and the next calculated value of the fixed time at marker B. Therefore, there is no information available during the drop, neither are correct values. For the rolling computations (with extension _rc) it can be seen though, that the calculation goes on and we still get values every 1 ms.





DEWETRON

REALTIME – GENERAL

Operating system = Ubuntu 24.04

CPU is realtime capable = Linux kernel version >= 6.12

DAQ realtime calculations enabled

Enable real-time computations

True

① Find the Realtime tab in the Advanced Settings of the Power Group

② Enable realtime calculations

③ New channels are available in the power group

ADVANCED SETTINGS

Harmonics

Flicker

Efficiency

d/q

Rolling

Realtime

①



Enable realtime calculation

Apply configuration

Cycle-Rate: 100 Hz

Averaging (periods): 1



UDP output

IP Address: 127.0.0.1

Port: 5000

Format: Default

Realtime

F_fund_rt

F_fund_rt

Updated_rt

Updated_rt

> Voltage (U)

> Current (I)

> Active Power (P)

> Reactive Power (Q)

> Apparent Power (S)

> Power Factor (PF)

> Waveform Data

③

The realtime channels cannot be displayed by the power group instrument

Note: Only is supported for Linux Ubuntu 24.04 systems with realtime capable CPU

See OXYGEN Power Realtime Manual for more information

OXY-OPT-POWER-realtime required



DEWETRON

© DEWETRON GmbH | August 26

REALTIME - Efficiency calculation

Operating system = Ubuntu 24.04

CPU is realtime capable = Linux kernel version ≥ 6.12

DAQ realtime calculations enabled



Enable real-time computations

True

① The speed channel must be a hardware channel. No software channel, like speed in the counter, can be used. Use the CNT channel instead and scale it to rpm

② Set the Counter input to mode = Frequency and

③ Scale to the counts to [rpm]
This means for 4 pulses per rotation, $60/4 = 15$



OXY-OPT-POWER-realtime required

EXERCISE – LET'S DO A ONE-PHASE POWER MEASUREMENT!

- > Go to the channel list
- > Create power group
- > Choose wiring
- > Assign channels
- > Enable additional analysis
- > Add the Power Instrument on the measurement Screen